

RFP 2022-02 GENERATOR REPLACEMENT

FLORIDA KEYS MOSQUITO CONTROL DISTRICT

QUESTIONS & ANSWERS

VENDOR 1

- 1) Bidders Acknowledgement Form:
 - a. Please confirm that a Certified/Cashier's check, or bid bond is NOT required to be submitted with this bid. **NOT REQUIRED**
- 2) For E-Verify:
 - a. Can I include a printout of our Company Profile screen for E-Verify enrollment? **YES**
 - b. Please confirm that the Affidavits from our subcontractors are to be submitted upon award. **CORRECT**
 - c. Do you have a specific Affidavit form you will require subcontractors to sign or do we use our own? **AFFIDAVIT IS ATTACHED AND CAN BE PROVIDED AT TIME OF AWARD.**
- 3) Proof of Adequate Insurance:
 - a. Do you have specific requirements for insurance coverages or shall we provide a Certificate of Insurance with our existing coverages? (owner to be added as additional insured upon award). **GENERAL LIABILITY INSURANCE FOR A LIMIT NO LESS THAN \$1,000,000.00. EXISTING COVERAGE FOR AUTOMOBILE INSURANCE AND WORKER'S COMP INSURANCE.**

VENDOR 2

- 1) RFP indicates replacing an 80 KW, 330 amp 120-208/3/60 generator with a 200 KW, 833 amp 120-208/1/60 generator. Is this correct or should it be an 80-100 KW unit which would provide 330-to 417 amps? *Unless you are planning an expansion that we are unaware.*
 - o Observation:
 - Existing service to the building is only 400 amps.
 - RFP is asking for a new 400 amp ATS, appropriately sized for the building service.
 - The generator sizing should be either 80 KW @ 330 amps, or 100 KW @ 417 amps. Please advise.
WE DO NOT PLAN TO EXPAND, WE WILL CONSIDER 80 KW TO 100 KW IF THIS IS SUITABLE FOR EXISTING POWER REQUIREMENTS.
- 2) Where do you want the new remote annunciator and mounted?
 - In the shop, like the old one. **YES, IN THE SHOP**
 - In the office or communications room?
- 3) RFP indicates a surface mount annunciator and also a flush mount kit.
 - If going in the garage, Surface mount might be the way to go,
 - If going in the office, flush mount may be the way to go.
 - Please advise. **CURRENTLY IN THE GARAGE, BUT WHATEVER IS BEST.**

VENDOR 3

- 1) What is the reason for a 1000 Amp circuit breaker on the generator?
WE WILL CONSIDER ANY SIZE SUITABLE FOR EXISTING POWER REQUIREMENTS. WE ENCOURAGE A SITE VISIT.